STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 113739
Permit No.
Basin 137B

NOTICE OF INTENT NO. 65804

1. OWNER **Round Mountain Gold Corp** **M/O-2010-9**
MAILING ADDRESS **PO Box 480**
Round Mtn, NV. 89045

ADDRESS AT WELL LOCATION **Round Mtn Mine**
Round Mtn, NV.
Subdivision Name: *County:* **Nye**

2. LOCATION **SE¼NE¼** Sec**30**T**10**N/ R**44**E
PERMIT/WAIVER NO. **M/O-1647**
Issued by Water Resources Parcel. No.

Latitude
Longitude
UTM E **493290** ☐ NAD 27
N **4283269** ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other PLUGGING

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey green granite		0	200	200
Grey green quartz		200	1005	805
38.699886°N NAD27				
117.077163°W				
Pumped hole full conventional				
with cement, cement top 40'.				
Hole is abandoned.				
Vibrating transducers 310' Bgs				
410' Bgs				
960' Bgs				

RECEIVED 2011 APR 26 AM 10:52 STATE ENGINEER

Date started: **March 6**, 20 **11**
Date completed: **March 21**, 20 **11**

7. *Water Level*
Static water level: **4.5** feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: **140** °F
Quality: **Good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		**1**

9. *WELL CONSTRUCTION*
Depth Drilled **1005** Feet Depth Cased **960** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	**0** Feet	**20** Feet
6 1/2 Inches	**20** Feet	**1005** Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	**3.65**	**.188**	**+1**	**960'**

Perforations:
Type of perforation **None**
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	0 to 40	☒ Pumped	☐ Poured
☒ Cement Grout	40 to 1005	☒ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured
Gravel Pack: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			
Bentonite Chips: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Boart Longyear** (CONTRACTOR)
Address **2745 W. California Ave** (CONTRACTOR)
Salt Lake City, UT 84101
Nevada contractor's license number issued by the *State Contractor's Board* **0021976**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2339**
Signed
By driller performing actual drilling on site or contractor
Date **March 30, 2011**

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com