STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113740
Permit No.
Basin 137 B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65804

1. OWNER **Round Mountain Gold Corp** **M/O-2010-8**
MAILING ADDRESS **PO Box 480**
Round Mtn, NV. 89045

ADDRESS AT WELL LOCATION **Round Mtn Mine**
Round Mtn, NV.
Subdivision Name: *County:* **Nye**

2. LOCATION **SE¼NE¼** Sec**30**T**10**N/ R**44**E
PERMIT/WAIVER NO. **M/O-1647**
Issued by Water Resources Parcel. No.

Latitude
Longitude
UTM E **493303** ☒ NAD 27
N 4283290 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Plugged

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	15	15
Type 3 Lithic/Rich Tuff		15	130	115
Type 8 Granite		130	800	670
38.700075°N NAD27				
117.007014°W				
Installed a 2" tremmie pipe with Transducer attached at 800', 540',240'. Pumped cement grout through 2" until it reached the surface. Then put in a tremmie pipe to 10' & pumped cement for 10'cement seal.				
Hole is abandoned				

Date started: **February 27**, 20 **11**
Date completed: **March 6**, 20 **11**

7. *Water Level*
Static water level: **10.7** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
Water Temperature: **135** °F
Quality: **Good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		1

9. *WELL CONSTRUCTION*
Depth Drilled **820** Feet Depth Cased **800** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	**0** Feet	**20** Feet
6 1/2 Inches	**20** Feet	**820** Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	**3.65**	**.189**	**+1**	**800**

Perforations:
Type of perforation **None**
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No

☐ Neat Cement	0 to 10	☒ Pumped	☐ Poured
☐ Cement Grout	10 to 820	☒ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured
Gravel Pack: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			
Bentonite Chips: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Boart Longyear** (CONTRACTOR)
Address **2745 California Ave.** (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the *State Contractor's Board* **0021976**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2376**
Signed
By driller performing actual drilling on site or contractor
Date **March 30, 2011**

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com