STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113754
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35840

1. OWNER Pilger Darwin D & Gayle Fam; ETT enterprise LLC
MAILING ADDRESS 5195 Las vegas Blvd S.
ADDRESS AT WELL LOCATION 6176 S. Las Vegas Blvd
R2 Paradise

2. LOCATION SE ¼ SE ¼ Sec 32 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-32-802-052 (Issued by Water Resources) Parcel No.
Latitude 36.073930 Longitude 115.173259
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	12	12
Caliche		12	14	2
Sandy Silt		14	17	3
Silty Clay		17	20	3
Gravel with Sand		20	21	1
Silty Clay		21	27	6
Gravel with Sand		27	30	3
Caliche		30	36	6
Clayey Silt		36	39	3
Silty Sand		39	42	3
Silty Clay		42	50	8
Caliche		50	51	1
Silty Clay		51	58	7
Sandy Clay		58	90	32

DCNR/DWR
RECEIVED
APR 25 2011
LAS VEGAS OFFICE

Date started 21-Mar , 20 11
Date completed 21-Mar , 20 11

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		.5

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	90	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	0	90

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 40 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 38
Placement Method: ☐ Pumped ☑ Poured
Gravel Packed: ☑ Yes ☐ No
From 38 feet to 90 feet
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 739 W. Sunset Rd (Contractor)
Henderson, NV 89011
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 4-22-11

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY