

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

**OFFICE USE ONLY**  
Log No. 113819  
Permit No. \_\_\_\_\_  
Basin 148

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 65911

1 OWNER City of Yerington ADDRESS AT WELL LOCATION 20 South California St.  
MAILING ADDRESS 102 South Main St. Yerington, NV. 89447  
Subdivision Name \_\_\_\_\_ County Lyon

2 LOCATION SW 1/4 SW 1/4 Sec 14 T 13N N/S/R 25 E Latitude 38 59.189N UTM E \_\_\_\_\_  NAD 27  
PERMIT/WAIVER No. attached 1061-199-11 Longitude 119 09.604W N \_\_\_\_\_  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
Is this well being plugged because a replacement well was drilled? no  
Is there an existing well log? no  
If yes, what is replacement well NO? \_\_\_\_\_ If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION  
Depth Drilled n/a Feet Depth Cased 90 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	0	90

Existing Perforations:

Type of perforation	Size of perforation	From	To
	n/a		
	n/a		
		feet to	feet

5 WATER LEVEL  
Static water level 8.2' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

6 Additional Notes or Comments

Installed 2" pipe in well and blew out fill from 82' to a depth of 90' where we hit a hard bottom. We then installed 8" Mills Knife and perforated casing with 6 rows per foot from 50' to surface. Wethen installed tremme pipe to 84', mixed 42 bags of Type II cement with approx. 210 gallons of water and pumped through tremme pipe from bottom of well to the surface.

2011 MAY 11 AM 11:31  
STATE ENGINEER

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made:  
Additional Perforations:

Type of perforater used: Mills Knife

From	To	Number of perfs per linear foot
0	50	6

8 WELL PLUGGING MATERIALS

From	To	Material Used	Quantity
90	0	neat cement <input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured	
		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	
		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	
		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	
		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	
		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	

Neat Cement Fluid Weight 14.3 lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite

Date Started 3/10/2011  
Date Completed 3/10/2011

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Carson Pump, LLC Contractor  
Address P.O. Box 20159 Contractor  
Careson City, NV. 89721

Nevada contractor's license number issued by the State Contractor's Board 39920A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2265

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 3/29/2011

Rev 05-06 USE ADDITIONAL SHEETS IF NECESSARY 38.986566°N  
119.159014°W  
NAD 27 (T)