WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 113858
Permit No. 45899, 41482
Basin 071
(replaces No. #34343)
NOTICE OF INTENT NO. 34339

1. OWNER PATRICIA E BERRY
MAILING ADDRESS 2900 VANDIEST RD
WINCA, NV. 89445

ADDRESS AT WELL LOCATION 2900 VANDIEST RD

2. LOCATION SE ¼ NE ¼ Sec. 23 T. 34 N/S R. 37 E. PERSHING County
PERMIT NO. 45899 + 41482 (Issued by Water Resources) | 09-140-07 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	5	5
CLAY		5	10	5
DRY GRAVEL / CLAY		10	20	10
BROWN CLAY		20	60	40
GREY CLAY		60	62	2
FINE GRAVEL / COURSE SAND	63	62	68	6
BROWN CLAY / SEAMS GRAVEL		68	80	12
SAND AND GRAVEL		80	92	12
BROWN CLAY WITH GRAVEL SEAMES		92	145	53
SAND AND GRAVEL		145	155	10
GREY CLAY / GRAVEL		155	160	5
SAND AND GRAVEL		160	165	5
GREY CLAY		165	168	3
SAND AND GRAVEL WITH CLAY SEAMS		168	198	30
SOFT BROWN CLAY		198	204	6

Date started 3/28/2000, 19
Date completed 4/20/2000, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	1	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 204 Feet Depth Cased 204 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	50 Feet
10 Inches		50 Feet	204 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		.250	0	204

Perforations:
Type perforation TORCH CUT
Size perforation 3/8 x 3
From feet to feet
From 200 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MCNINCH DRILLING (Contractor)
Address 8005 MCNINCH RD (Contractor)
WINNEMUCCA, NV. 89445
Nevada contractor's license number issued by the State Contractor's Board #0005437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1712
Signed Mike McNinch (By driller performing actual drilling on site or contractor)
Date 4/28/2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627