WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 113859
Permit No.
Basin 072

(replaces NOI #43274)
NOTICE OF INTENT NO. #43276

1. OWNER LAWSON BROOKS
MAILING ADDRESS E. FRONTAGE ROAD
IMLAY NEVADA 89418

ADDRESS AT WELL LOCATION Lot 9 - Blk P
E. FRONTAGE ROAD
IMLAY, NV. 89418

2. LOCATION NW ¼ NW ¼ Sec. 5 T. 32 N/S R. 35 E. PERSHING County
PERMIT NO. (Issued by Water Resources) Lot 9 Block P (Parcel No.) Mill City (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
DRY GRAVEL / COBBLES		2	15	13
BROWN CLAY / GRAVEL		15	50	35
BROWN CLAY / GRAVEL CEMENTED (HARD)		50	80	30
SOFT BROWN CLAY		80	110	30
SOFT BROWN CLAY GRAVEL SEAMS	115	110	135	25
SAND + GRAVEL / CLAY		135	170	35
COURSE SAND + GRAVEL SEAMS BROWN CLAY		170	200	30

2011 MAY 17 AM 11:50 STATE ENGINEER

Date started 2-10-02, 19
Date completed 2-15-02, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	60' TO 130	2 HR

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation SAW SLOT
Size perforation 1/8 x 2
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From — feet to — feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MCNINCH DRILLING (Contractor)
Address 8005 MCNINCH RD (Contractor)
OMCA, NV. 89445
Nevada contractor's license number issued by the State Contractor's Board #0005437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1712
Signed Mike McNinch (By driller performing actual drilling on site or contractor)
Date 2/20/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (09-627)