STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 113888
Permit No.
Basin

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 35820

1 OWNER Herbst Development LLC %T Herbst
MAILING ADDRESS 5195 Las Vegas Blvd S.
Las Vegas, NV 89119-3209

ADDRESS AT WELL LOCATION 1500 W. Charleston Blvd
MW-17 Las Vegas, NV
Subdivision Name: County: Clark

2 LOCATION SE ¼ SW ¼ Sec 33 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-33-411-019
Issued by Water Resources Parcel No.

Latitude 36. 09'32.90"
Longitude 115. 09'40.74"
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3 TYPE OF WELL
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled? No
If yes, what is replacement well NOI?

Is there an existing well log? N/A
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled n/a Feet Depth Cased 25 Feet

EXISTING CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | | Sch 40 | 0 | 25 |
| | | | | |
| | | | | |
| | | | | |

Existing Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02

| | | | | |
|---|---|---|---|---|
| From | 10 | feet to | 25 | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |

5 WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

6 Additional Notes or Comments

Knocked out bottom of well, tremie neat cement from bottom up, pulled casing concrete cap surface

DCNR/DWR
RECEIVED
APR 28 2011
LAS VEGAS OFFICE

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☒ yes ☐ no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? ☐ yes ☒ no
Was the casing pulled? ☒ yes ☐ no
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:

Additional Perforations:
Type of perforater used: n/a

| | | | | | |
|---|---|---|---|---|---|
| From | | feet to | | feet | Number of perfs per linear foot |
| From | | feet to | | feet | Number of perfs per linear foot |
| From | | feet to | | feet | Number of perfs per linear foot |
| From | | feet to | | feet | Number of perfs per linear foot |
| From | | feet to | | feet | Number of perfs per linear foot |
| From | | feet to | | feet | Number of perfs per linear foot |

8 WELL PLUGGING MATERIALS

| | | | | | Material Used | | |
|---|---|---|---|---|---|---|---|
| From | 0 | feet to | 25 | feet | Neat Cement | ☒ Pumped | ☐ Poured |
| From | | feet to | | feet | | ☐ Pumped | ☐ Poured |
| From | | feet to | | feet | | ☐ Pumped | ☐ Poured |
| From | | feet to | | feet | | ☐ Pumped | ☐ Poured |
| From | | feet to | | feet | | ☐ Pumped | ☐ Poured |
| From | | feet to | | feet | | ☐ Pumped | ☐ Poured |

Neat Cement Fluid Weight 94/5.2 lbs/gal
Bentonite Grout % bentonite
Date Started 4/21/2011
Date Completed 4/21/2011

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 739 W. Sunset Rd
Contractor
Henderson. NV 89011
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed
By driller performing actual drilling on site or contractor
Date 4-28-11

(Rev. 05-06)

**USE ADDITIONAL SHEETS IF NECESSARY**