STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113913
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64362

1. OWNER Rick Kennel
MAILING ADDRESS 73-4358 Ahiahi Street
Kailua/Kona, HI 96740

ADDRESS AT WELL LOCATION 220 East Ward Mt. Drive
Ely, Nv 89831

2. LOCATION NE ¼ NE ¼ Sec 23 T 14N N/S R 63 E
PERMIT/WAIVER No. Ø12-110-13 (Issued by Water Resources) Parcel No.

Latitude 39° 04.07N
Longitude 114° 51. 35W
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: White Pine

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	10	10
Fractured Limestone		10	15	5
Sandstone		15	30	15
Limestone		30	170	140
Sandstone	X	170	180	10
Limestone		180	290	110
Conglomerate	X	290	325	35
Granite		325	360	35
Conglomerate	X	360	380	20
Limestone		380	400	20
Sandy Gravel	X	400	450	50

Date started 27-Sep, 20 09
Date completed 29-Sep, 20 09

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	56-60		6 hrs

8. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 430 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	10	Feet
8 5/8	Inches	10	Feet	430	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	Steel	188	+2	18
6	PVC	SDR 21	18	430

Perforations:
Type of perforation Machine
Size of perforation 3/16" x 3"
From 390 feet to 430 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 430 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel "Clay" Fertig Jr. dba Fertig Drilling Company (Contractor)
Address P.O. Box 523 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *onsite driller* 2367
Signed (By driller performing actual drilling on site or contractor)
Date OCT-16-09

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

39.067891°N
114.854985°W NAD27

MMH-(F)