STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113927
Permit No.
Basin 089

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

*Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 65926

1. OWNER Nicole Reynolds
MAILING ADDRESS 2960 Eagle Street WV NV 89704
ADDRESS AT WELL LOCATION 2940 Hawk St. WV NV 89704

2. LOCATION ~~NE~~ NW ¼ SE ¼ Sec 31 T 17N N/S R 20 E
PERMIT/WAIVER No. 050-407-08 *issued by Water Resources*
Parcel No.
Latitude 39.29222 Longitude 119.77721
UTM E N
☑ NAD 27 ☐ NAD 83/WGS 84
Subdivision Name: County: WASHOE

3. WORKED PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other...

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Clay | | 0 | 116 | 116 |
| Med Granit | | 116 | 215 | 99 |
| Hard Granit | | 215 | 310 | 95 |
| Fractured Granit | x | 310 | 335 | 25 |

Date started 5/9/2011 , 20
Date completed 5/19/2011 , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 50+ | | 3 |

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased 335 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 11" | Inches | 0 | Feet | 215 | Feet |
| 5 3/4" | Inches | 215 | Feet | 335 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8" | 13 | .188 | 1 | 19 |
| 6" | 4 | SDR21 | 19 | 215 |
| 5" | 10 | .188 | 115' | 335' |

Perforations:
Type of perforation Factory cut
Size of perforation 3/32"
From 140 feet to 160 feet
From 200 feet to 215 feet
From 315 feet to 335 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 215 feet

9. WATER LEVEL
Static water level 58' feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address PO Box 1255 CC NV 89702 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 46498
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2134
Signed (By driller performing actual drilling on site or contractor)
Date 5/19/2011

(Rev. 06/10)
**USE ADDITIONAL SHEETS IF NECESSARY**

39.292220°N
119.777210°W
NAD 27 TA