STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 139929
Permit No. 78265
Basin 188

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67109

1. OWNER Jim Boyer/Pequop Conservancy, LLC
MAILING ADDRESS P.O. Box 7335
Reno, NV 89210

ADDRESS AT WELL LOCATION North of I-80
Approx 1 mile west of Honor Farm

2. LOCATION NW ¼ NW ¼ Sec 11 T 37N N/S R 64 E
PERMIT/WAIVER No 78265 (Issued by Water Resources) Parcel No.

Latitude 41. 06. 594N
Longitude 114. 43. 063W
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Elko

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☑ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other... Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	13	13
Brown Clay		13	25	12
Gravel/Clay Mix		25	45	20
Cemented Gravel		45	65	20
Loose Gravel		65	68	3
Cemented Gravel		68	75	7
Clay & Gravel Mix		75	120	45
Tan Clay		120	126	6
Cemented Gravel		126	128	2
Loose Gravel	X	128	130	2
Limestone		130	145	15
Cemented Gravel		145	167	22
Rhyolite		167	170	3
Loose Gravel	X	170	182	12
Cemented Gravel		182	190	8
Limestone		190	220	30

Date started 5-May-11, 20
Date completed 10-May-11, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	60		14

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.94	188	+2	20

Perforations:
Type of perforation Mill Slot
Size of perforation 3/16" x 3"
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 51 feet to 220 feet

Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig dba Fertig Drilling Company (Contractor)
Address P.O. Box 525 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 5-25-11

(Rev. 06/10) USE ADDITIONAL SHEETS IF NECESSARY

41.109977°N
114.716847°W
NAD 27 (TS)