STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113949
Permit No.
Basin 089

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67226

1. OWNER DON DREW / Christopher + Kristine Drew
MAILING ADDRESS 3420 CHURCH HILL DR
SE NEW WASHOE CITY, NV 89704

ADDRESS AT WELL LOCATION 3420 CHURCH HILL DR
NEW WASHOE CITY, NV 89704
Subdivision Name: County: Washoe

2. LOCATION ~~NE~~ ¼ ~~SW~~ ¼ Sec 6 T 16N N/S R 20 E
PERMIT/WAIVER No. NE 050-445-03
Issued by Water Resources Parcel No.

Latitude 39.28251*N
Longitude 119.77086*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL		0	90	90
COURSE DG SANDS		90	127	37
BROWN SANDY CLAY		127	138	11
COURSE DG SANDS		138	170	32
HARDER DG SANDS				
GRAVELS	XX	170	190	20
+ original log being deepened - unknown				

Date started: 23-May, 20 11
Date completed: 24-May, 20 11

9. WELL CONSTRUCTION
Depth Drilled (190) 100 Feet Depth Cased (190) 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	90 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.82	.216	70	190
SDR 21				

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .032
From 150 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 65 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	30	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address #20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 05/27/2011

(Rev. 03-08)

USE ADDITIONAL SHEETS IF NECESSARY

39.282599°N
119.769843°W
NAD27

mmH ⓔ