

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59946

1. OWNER Douglas Carson ADDRESS AT WELL LOCATION WRJ 84  
 MAILING ADDRESS MC 34 Box 34153 N 38° 51.326' W 115° 02.813'  
ELY, NV 89301  
 2. LOCATION NW 1/4 SE 1/4 Sec. 31 T 12 N/S R E 1/2 White Pine County  
 PERMIT NO. 2840-(Leck) Parcel No. 13-122-03 Lund ten acre plat Subdivision Name  
 # 10618 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Starting point</u>				
<u>Existing well 16" cased to 66'</u>				
<u>Sand-gravel - clay conglomerate</u>		<u>66</u>	<u>100</u>	
<u>gravel</u>	<u>water</u>	<u>100</u>	<u>101</u>	<u>1</u>
<u>Silty clay</u>		<u>101</u>	<u>119</u>	
<u>gravel</u>	<u>water</u>	<u>119</u>	<u>121</u>	<u>2</u>
<u>Silty clay</u>		<u>121</u>	<u>135</u>	
<u>gravel</u>	<u>water</u>	<u>135</u>	<u>136</u>	<u>1</u>
<u>clay</u>		<u>136</u>	<u>139</u>	
<u>gravel</u>	<u>water</u>	<u>139</u>	<u>141</u>	<u>2</u>
<u>clay</u>		<u>141</u>	<u>163</u>	
<u>gravel gravel</u>	<u>water</u>	<u>163</u>	<u>164</u>	<u>1</u>
<u>clay</u>		<u>164</u>	<u>171</u>	
<u>gravel</u>	<u>water</u>	<u>171</u>	<u>172</u>	<u>1</u>
<u>clay</u>		<u>172</u>	<u>181</u>	

2011 MAY 26 AM 11:54

8. WELL CONSTRUCTION  
 Depth Drilled 181 Feet Depth Cased 181 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 15 Inches To 181 Feet  
 From 66 Feet To 181 Feet  
 From 181 Feet To 181 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.75</u>		<u>250</u>	<u>0</u>	<u>181</u>

Perforations:  
 Type perforation mill  
 Size perforation 12 row 1/8" x 2.5"  
 From 52 feet to 173 feet  
 From 173 feet to 181 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal.....  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 181 feet

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow..... G.P.M. .... P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Maynard Well Drilling Contractor  
 Address Po Box 64 Lund NV 89317 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 047224  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554  
 Signed Owner Maynard  
 By driller performing actual drilling on site or contractor  
 Date May 22-11

Date started Feb 28, 2011  
 Date completed April 29, 2011

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80</u>	<u>0</u>	<u>1hr</u>