

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 113958
Permit No.
Basin 054

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. LE0184

1. OWNER PLOTS (USA) Inc ADDRESS AT WELL LOCATION Cortez Goldmine
MAILING ADDRESS Hwy 50 State route
Beowawe, NV 89821
2. LOCATION NE 1/4 NW 1/4 Sec 33 T. 28 N. S. R. 47 E. lander County
PERMIT NO. m/0-1003 Parcel No. 40°15.731 N 116°40.901 W nad 27

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG 4BH-5

| Material | Water Strata | From | To | Thickness |
|--|--------------|------|----|-----------|
| pump grouted to surface and overdrilled with 6" auger to 35' twisted auger off and pump grouted from 32' to surface. | | | | |
| 18.5 bags of cement 47 lbs. 15.2 lbs/gal | | | | |
| 40.262183°N NAD27 116.681683°W | | | | |

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
2 PVC Sch 80 0 87.5
Perforations:
Type perforation pac
Size perforation 020
From 67.5 feet to 87.5 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 5/10, 2011
Date completed 5/10, 2011

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| <u>N/A</u> | | | |

9. WATER LEVEL
Static water level no water feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Drilling Contractor
Address 1035 Belford rd. Contractor
Reno, NV 89509
Nevada contractor's license number 34525
issued by the State Contractor's Board.
Nevada driller's license number issued by the 1028
Division of Water Resources, the on-site driller.
Signed Andy Andresen
By driller performing actual drilling on site or contractor
Date 5/23/11

