WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 113970
Permit No. 52442
Basin 101

NOTICE OF INTENT NO. 50516

1. OWNER Tenneco Minerals Co
MAILING ADDRESS 5301 Longly
Reno NV 89511

ADDRESS AT WELL LOCATION
PLUGGING NDWR WELL LOC# 30710

2. LOCATION NW ¼ SW ¼ Sec. 1 T 22 N/S R 33 E Churchill County
PERMIT NO. 52442 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Attempts to pull well				
casing failed.				
A 8 inch mills knife				
was used to perforat				
the well from 290 ft				
to 51 ft.				
1 1/4 inch tremie pipe				
was set 295 ft and				
neat cement was pump				
to surface.				

RECEIVED 2011 JUN -8 AM 11:34 STATE ENGINEER'S OFFICE

Date started 4/16/, 2004
Date completed 4/17, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ~~350~~ 309 Feet Depth Cased ~~350~~ 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches	0 Feet	350 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"			+3	300

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 51 ft
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Knoblock & Sons Pump and Supply (Contractor)
Address 11375 Campo Rico Ln (Contractor)
Sparks NV 89441
Nevada contractor's license number issued by the State Contractor's Board 49162
Nevada driller's license number issued by the Division of Water Resources, the on-site driller AB-2213
Signed (By driller performing actual drilling on site or contractor)
Date 6/3/2011

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627