STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113979
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63222

1. OWNER Denise Delong & Norman Tompson
MAILING ADDRESS 10725 Spur St
Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 10725 Spur St.
Winnemucca NV. 89445
Subdivision Name: Rawhide Estates County: Humboldt

2. LOCATION SE ¼ NE ¼ Sec 31 T 35N N/S R 38 E
PERMIT/WAIVER No. 010-626-07
Issued by Water Resources
Parcel No.

Latitude N 40' 52.031
Longitude W 117'44.360
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay and cobbles		0	120	
cemented gravels w/clay		120	340	220

Date started: 5-Jun, 20
Date completed: 6/6/2011, 20

9. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	340	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	340

Perforations:
Type of perforation millslot
Size of perforation .090 X3"
From 260 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	5	to 160	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 160 to 340 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 160 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		4 hr

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Stonehouse Drilling & Const. (Contractor)
Address 3885 Wedekind Rd. Sparks NV. 89431 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0069994
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed [signature] office
By driller performing actual drilling on site or contractor
Date 6/8/11

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

40.867279°N
117.738371°W NAD27 (TA)