

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 114025  
Permit No. \_\_\_\_\_  
Basin φ64

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

63099  
NOTICE OF INTENT NO.

1. OWNER Eddie King  
MAILING ADDRESS 1100 Allen Rd  
BATTLE MTN NV 89820  
2. LOCATION NW 1/4 NW 1/4 Sec 14 T32 N3R44 E  
PERMIT/WAIVER No. \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

ADDRESS AT WELL LOCATION 1050 Allen Rd  
BATTLE MTN  
Subdivision Name: \_\_\_\_\_ County: HANDEN  
Latitude UTM E 500639  NAD 27  
Longitude N 4500083  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>TOP Soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Rocky clay</u>		<u>5</u>	<u>20</u>	<u>15</u>
<u>SANDY CLAY</u>		<u>20</u>	<u>40</u>	<u>20</u>
<u>Blue Rocky Clay</u>		<u>40</u>	<u>100</u>	<u>60</u>
<u>Brown Rocky Clay</u>		<u>100</u>	<u>180</u>	<u>80</u>
<u>Blue Rocky Clay</u>		<u>120</u>	<u>180</u>	<u>60</u>
<u>Brown Clay</u>		<u>180</u>	<u>200</u>	<u>20</u>
<u>SOFT TAN Rocky Clay</u>		<u>200</u>	<u>230</u>	<u>30</u>
<u>SAND + GRAVEL W. CLAY</u>		<u>220</u>	<u>250</u>	<u>30</u>

9. WELL CONSTRUCTION  
Depth Drilled 250 Feet Depth Cased 250 Feet  
HOLE DIAMETER (BIT SIZE)  
10 3/8 Inches From 0 Feet To 250 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>71</u>	<u>250</u>

Perforations:  
Type of perforation: Torch cut  
Size of perforation: 3/16 x 5  
From 170 feet to 250 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 5 to 60  Pumped  Poured  
 80% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 150 to 250  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No 60 to 150  Pumped  Poured  
Type: 3/8

7. Static water level: 40 ft Water Level feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: Cold °F  
Quality: Good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Rotary</u>	<u>40+</u>	<u>Varies</u>	<u>3 Hrs</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LBJ DRILLING & PUMP COMPANY, INC. Contractor  
Address P.O. BOX 902 - Winnemucca, NV 89446 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0009605A  
Nevada driller's license number issued by the Division of Water Resources 1807  
Signed Joe Boggio By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_

USE ADDITIONAL SHEETS IF NECESSARY 40.653507°N NAD 27  
116.992205°W 100