

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 114142
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35536

1. OWNER Santa Barbara palms LP ADDRESS AT WELL LOCATION 4880 Santa Barbara Street
 MAILING ADDRESS 2655 S. Rainbow Blvd. #401 Las Vegas, NV

2. LOCATION SE 1/4 SE 1/4 Sec 19 T 21 S R 62 E Clark County

PERMIT NO. 161-19-803-001
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1-40' Dewater well				
Aluviam		0	3	3
Silt		3	12	9
Sandy Silt	x	12	14	2
Silty clay		14	32	18
Clay		32	40	8
Waiver# DW-1321				
WSG84				
N36 06. 106'				
W115 04. 987'				

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
24 Inches 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	37	1/4	0	40

Perforations:
 Type perforation Machine
 Size perforation 1/4"
 From _____ 20 feet to _____ 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ 0 feet to _____ 40 feet

9. WATER LEVEL

Static water level _____ 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 6/15, 20 11
 Date completed 6/21, 20 11

Name ALLEN DRILLING INC.
 (CONTRACTOR)

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
	Draw Down		Time (Hours)
G.P.M.	(Feet Below Static)		

Address 4015 WEST TOMPKINS AVE.
 (CONTRACTOR)

LAS VEGAS, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231-Victor Estes

Signed Victor Estes
 By driller performing actual drilling on site or contractor

Date July 18, 2011