STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114222
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67273

1. OWNER ARNOLD BECK CONSTRUCTION
MAILING ADDRESS 247 GREENCREST DRIVE
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 592 FOUR MILE TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION NW ¼ SW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09P-017
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602101 [X] NAD 27
N 4517374 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	5	5
ROCKS, SAND AND GRAVEL		5	55	50
TAN CLAY AND GRAVEL		55	80	25
TAN CLAY		80	100	20
BLUE GREY CLAY		100	200	100
BLUE GREY CLAY	X	200	249	49

Date started: 25-Jul, 20 11
Date completed: 26-Jul, 20 11

RECEIVED 2011 AUG -8 PM 1:09 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 249 Feet Depth Cased 249 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	249	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1	249

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4 1/2", 7 ROWS
From 228 feet to 249 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 15 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 249 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 15 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 85 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125 PSI @			
825 CFM	50		2 HOURS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed Dale C. Vedder (By driller performing actual drilling on site or contractor)
Date 7/26/2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY 40,802930°N
-115,789623°W
NAD 27 (T)