STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114226
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67521

1. OWNER MARY COLLIER
MAILING ADDRESS 2315 KINKADE
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 2315 KINKADE
MINDEN, NV 89423
Subdivision Name: County: Douglas

2. LOCATION SW ¼ NE ¼ Sec 11 T 13N N/S R 20 E
PERMIT/WAIVER No. 1320-11-001-020
Issued by Water Resources Parcel No.

Latitude 39.00658*N
Longitude 119.70164*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		0	140	140
COURSE DG SANDS		140	165	25
SILTY CLAY		165	229	64
DG SANDS	XX	229	300	71

Date started: 29-Jul, 20 11
Date completed: 01-Aug, 20 11

RECEIVED 2011 AUG 11 PM 1:11 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 300 ~~160~~ Feet Depth Cased 300 ~~160~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	140	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.26	.216	100	300

Perforations:
Type of perforation FACTORY NILL SLOT
Size of perforation .032
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 90 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	35	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPTIAL CITY WELL DRILLING AND PUMPSERVICE INC.
Contractor
Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael Wack
By driller performing actual drilling on site or contractor
Date 08/05/2011

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

39.006671°N
-119.700631°W
NAD 27 (TA)