STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114247
Permit No.
Basin 129

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67260

1. OWNER AYSD company,LLC
MAILING ADDRESS 5245 Vista Blvd F3-327
Sparks NV 89436

ADDRESS AT WELL LOCATION 4103 Kyle hot springs
Road Unionville NV 89418
Subdivision Name: Pacel Of Land County: Pershing

2. LOCATION NE¼ SW ¼ Sec 25 T 30 N/S R 35 E
PERMIT/WAIVER No. 012-110-36
Issued by Water Resources Parcel No.

Latitude N40°26'29.4" UTM E ☐ NAD 27
Longitude W117°59'52.9" N ☑ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	10	10
GRAY,CLAY,GRAVELS		10	25	15
GRAY,CLAY		25	40	15
CONSOLIDATED,SAND		40	80	40
CLEAN,SANDS		80	140	60

Date started: 6-27 , 20 11
Date completed: 7-11 , 20 11

RECEIVED 2011 AUG 11 AM 9:45 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 142 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12	.188	+ 2	9
6	4.06	.316	9	140

Perforations:
Type of perforation FACTORY CUT
Size of perforation CL 6" SDR21 Screen .032
From 70 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 10 ■ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
■ ≥30% Bentonite Grout 10 to 50 ■ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 140 ☐ Pumped ☐ Poured
Type: ¼ GRAVELS
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 27 feet below land surface
Artesian Flow: N/A G.P.M. 30 P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
120 PSI	30		4 HRS
185 CFMS			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name INDUSTRIAL DRILLING, INC. (Contractor)
Address 5245 Vista Blvd,F3-327 (Contractor)
Sparks NV 89436
Nevada contractor's license number issued by the State Contractor's Board 76130
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2289
Signed Tobias R. Trujillo (By driller performing actual drilling on-site or contractor)
Date 7-19-11

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY 40.441591°N -117.997060°W NAD 27 (T9)

(NSPO 3-08) (O) 627