STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114352
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67524

1. OWNER SALLY BELL
MAILING ADDRESS 1600 MANCHESTER CR
FALLON, NV 89409

ADDRESS AT WELL LOCATION 1600 MANCHESTER CR
FALLON, NV 89409 6 (TA) 9/22/11
Subdivision Name: County: Churchill

2. LOCATION SE ¼ NW ¼ Sec 36 T 19N N/S R 28 E
PERMIT/WAIVER No. DOM11-07 010-033-08
Issued by Water Resources Parcel No.

Latitude 39.46803*N
Longitude 118.79510*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
COURSE DG SANDS		3	46	43
COURSE GRAVELS	X	46	72	26
BROWN CLAY		72	83	11
COURSE DG SANDS	XX	83	120	37

RECEIVED 2011 SEP 13 AM 11:19 STATE ENGINEER'S OFFICE

Date started: 15-Aug, 20 11
Date completed: 17-Aug, 20 11

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	40	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	1	20
6 5/8	4.26	.216	20	120
sdr 21				

Perforations:
Type of perforation FACTORY SLOT
Size of perforation 3 X 3/32
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 120 ☐ Pumped ☒ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed (By driller performing actual drilling on site or contractor)
Date 09/07/2011

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

39,468,161°N
-118.794,144°W
NAD 27
(TA)