

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114375
Permit No. _____
Basin 176

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66983

1. OWNER Narrin Gold Strike
MAILING ADDRESS PO Box 2706 ELKO NV 89803

ADDRESS AT WELL LOCATION Baldwin
Lower Boise
Subdivision Name: _____
County: White Pine

2. LOCATION SW 1/4 SW 1/4 Sec 7 T24 R58 E
PERMIT/WAIVER No. MO-1651-A P2-1042
Issued by Water Resources Parcel No.

Latitude _____ UTM E 628592 NAD 27
Longitude _____ N 4424969 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Inspersed Silty Sand</u>	<u>←</u>	<u>6'</u>	<u>60'</u>	<u>60'</u>
<u>Domestic zone</u>		<u>60'</u>	<u>480'</u>	<u>420'</u>
<u>Water @ 860' 156pm</u>		<u>860'</u>	<u>480'</u>	<u>480'</u>
<u>Water @ 960' 256pm</u>				
<u>1/4 Gravel 60 50# bags</u>				
<u>3/4 hole plug 184" "</u>				
<u>pel plug 6 566</u>				
<u>Cement 6 94# bags</u>				

Date started: 6/5/11, 20
Date completed: _____, 20

9. WELL CONSTRUCTION

Depth Drilled 960' Feet Depth Cased 960' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>6 1/2"</u>	<u>0</u>	<u>960'</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>		<u>3/8</u>	<u>6</u>	<u>960'</u>

Perforations:

Type of perforation MACH
Size of perforation 1/8"

From 860' feet to 960' feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 230% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 860' to 960' Pumped Poured
Type: 1/4 Gravel Trimed From 960' - 860'

Bentonite Chips: Yes No 960' to 6' Pumped Poured
Type: 3/8 Hole plug

7. Water Level
Static water level: 734' feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA °F
Quality: Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boat Longyear Nevada
Contractor
Address PO Box 2748
Contractor
Elko, NV 89803

Nevada contractor's license number
issued by the State Contractor's Board 0073086

Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 1395

Signed [Signature]
Driller performing actual drilling on site or contractor
Date 6/14/11

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>23</u>	<u>NA</u>	<u>2 Hr</u>