STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114413
Permit No. 80794T
Basin 222

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

65830

1. NV State Parks
901 So. Stewart St.
Carson City NV

Beaver DAM
State Park

2. SE NW 17 5 0 71
80794T | 01408006
Issued by Water Resources | Parcel No.

N 37° 30.55.8
W 114° 4.55.7
Subdivision Name

☐
☐
County: Lincoln

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
Recreation DSB
~~☒ Domestic~~ ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other...

6. LITHOLOGIC LOG

Material		From	To	Thickness
Top Soil		0	1	1
Dry firm Clay		1	24	23
Red Rock		24	60	36
Altered Sandstone	X	60	198	138

DCNR/DWR
RECEIVED
SEP 01 2011
LAS VEGAS OFFICE

Date Started 7-26, 2011
8-2, 2011

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. Depth Drilled 198 Feet Depth Cased 198 Feet

	From	To
10 3/4 Inches	0 Feet	~~50~~ Feet
Inches	Feet	198 Feet
Inches	Feet	Feet

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17	.250	+2	198

Type of perforation Mill slot
Size of perforation .080
From 98 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 198 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. 37'8" feet below land surface
Artesian flow NO G.P.M 25 P.S.I
Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Corp
Contractor
Address P.O. Box 888
Contractor
Fallon NV 89406
Nevada contractor's license number issued by the 11752
Nevada driller's license number issued by the Division of Water Resources, the 2199

Jesus Marizcurrena
By driller performing actual drilling on site or contractor
8-2-11

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY