

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 114420
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 35956
PUBLIC RIGHT OF WAY

1 OWNER CITY OF LAS VEGAS NV.
MAILING ADDRESS 400 STEWART AVE
LAS VEGAS NV.

ADDRESS AT WELL LOCATION _____
Subdivision Name: _____ County: CLARK

2 LOCATION SE 1/4 SE 1/4 Sec 06 T 21 N R 61 E
PERMIT/WAIVER No 16206899 004
Issued by Water Resources Parcel No _____

Latitude 36° 08' 45.4" N UTM E NAD 27
Longitude 115° 11' 27.6" W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____
Is there an existing well log? NO
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCH 40</u>	<u>0</u>	<u>15</u>

If well was not cleaned out to total depth, please explain why: UNACCESSIBLE WITH DRILLING BROKE UP IN PLACE + GROUTED

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 5 feet to 15 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: NONE
From _____ feet to _____ feet Number of perms per linear foot _____
From _____ feet to _____ feet Number of perms per linear foot _____
From _____ feet to _____ feet Number of perms per linear foot _____
From _____ feet to _____ feet Number of perms per linear foot _____
From _____ feet to _____ feet Number of perms per linear foot _____

5 WATER LEVEL
Static water level NONE feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 15 feet CEMENT GROUT Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments
MW 7

DCNR/DWR RECEIVED

AUG-22-2011

LAS VEGAS OFFICE

Neat Cement Fluid Weight 94 lbs/gal 5.2
Bentonite Grout _____ % bentonite
Date Started 8-15-2011
Date Completed 8-15-2011

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING Contractor
Address 7150 PLACID ST LAS VEGAS NV. Contractor 89119
Nevada contractor's license number _____
Issued by the State Contractor's Board 51269
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Neil J. Wiktor
By driller performing actual drilling on site or contractor
Date 8-15-2011