STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114422
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety, in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 35940

1. OWNER NEVADA ENVIROMENTAL
MAILING ADDRESS RESPONSE TR. 35 E. WALKER DR. 1550 CHICAGO ILL 60601-2124

ADDRESS AT WELL LOCATION UNICORP COUNTY
Subdivision Name: County: CLARK

2. LOCATION NW ¼ NW ¼ Sec 12 T 22 N/S R 62 E
PERMIT/WAIVER No. 178-12-104003 Issued by Water Resources
Parcel No.

Latitude 36 052963 N
Longitude 115 009758 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND + STONE	NO	0	34	34
SILTY SAND + GRAVEL	YES	34	42	8
SILTY CLAY	NO	42	46	4

MW 138
FACILITY ID NO.
H0000536

DCNR/DWR
RECEIVED
AUG 29 2011
LAS VEGAS OFFICE

Date started: 7-28, 20 11
Date completed: 7-28, 20 11

7. Water Level
Static water level: 32.5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 46 Feet Depth Cased 46 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	46 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 80	0	46

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .040
From 22 feet to 42 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement 10 to 18 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 0 to 10 ☐ Pumped ☒ Poured
☐ =30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 20 to 42 ☐ Pumped ☒ Poured
Type: NO 8
Bentonite Chips: ☒ Yes ☐ No 18 to 20 ☐ Pumped ☒ Poured
Type: 3/8"

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST. (Contractor)
LAS VEGAS NV. 89119 — D&B
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-16-2011

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY