STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114424
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 35940

1. OWNER NEVADA ENVIROMENTAL
MAILING ADDRESS RESPONSE TR. 35 E. WALKER DR. 1550 CHICAGO ILL 60601-2124

ADDRESS AT WELL LOCATION UNICORP COUNTY
Subdivision Name:
County: CLARK

DSB 2 LOCATION NW NW Sec 2 T 22 N/S R 62 E
PERMIT/WAIVER No. 178-12-101-003
Issued by Water Resources
Parcel No.

Latitude 36 053323 N
Longitude 115 010393 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + GRAVEL + STONE	NO	0	34	34
SILTY SAND + GRAVEL	YES	34	48	16
SILTY CLAY	NO	48	52	4

DCNR/DWR RECEIVED
AUG 29 2011
LAS VEGAS OFFICE

MW 136
FACILITY ID NO.
H-000536

Date started: 7-28, 20 11
Date completed: 7-28, 20 11

9. WELL CONSTRUCTION
Depth Drilled 52 Feet Depth Cased 52 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	52	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 80	0	52

Perforations
Type of perforation MACHINE SLOT
Size of perforation .040
From 28 feet to 48 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 10 to 24 ☐ Pumped ☒ Poured
☒ Concrete Grout 0 to 10 ☐ Pumped ☒ Poured
☐ =30% Bentonite Grout 48 to 52 ☐ Pumped ☒ Poured
Gravel Pack: ☒ Yes ☐ No 26 to 48 ☐ Pumped ☒ Poured
Type: No 8
Bentonite Chips: ☐ Yes ☐ No 24 to 26 ☐ Pumped ☒ Poured
Type: 3/8"

7. Water Level
Static water level 39 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING
Contractor
Address 7150 PLACID ST.
Contractor
LAS VEGAS NV. 89119 DSB
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed
By driller performing actual drilling on site or contractor
Date 8-16-2011

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY