

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 114429
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35951

1 OWNER THRIFTY PAYLESS INC 40 REALEST ADDRESS AT WELL LOCATION 3846 W. SAMARA
MAILING ADDRESS TAX # 6111 P.O. Box 3165 LAS VEGAS NV.
HARRISBURG PA. 17105-3165 Subdivision Name: _____ County: CLARK
2 LOCATION SE 1/4 SE 1/4 Sec 06 T 21 N 36 E Latitude 36° 08' 43.1 N UTM E _____ NAD 27
PERMIT/WAIVER No. 16204813006 Longitude 115° 11' 28.2 W N _____ NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____
Is there an existing well log? NO
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCH 40</u>	<u>0</u>	<u>40</u>

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: NONE
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

Existing Perforations:
Type of perforation MAXIMUM SLOT
Size of perforation 1.020
From 10 feet to 40 feet
From _____ feet to _____ feet

5 WATER LEVEL
Static water level 20.1 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 1 feet CONCRETE Pumped Poured
From 1 feet to 40 feet CEMENT GROUT Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments
MW4

DCNR/DWR RECEIVED

AUG 22 2011

LAS VEGAS OFFICE

Neat Cement Fluid Weight 94 lbs/gal 5.2
Bentonite Grout _____ % bentonite
Date Started 8-8-2011
Date Completed 8-8-2011

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING Contractor
Address 7150 PLACID ST. LAS VEGAS NV Contractor 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Mei J. Winter
By driller performing actual drilling on-site or contractor
Date _____