STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114444
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36057

1. OWNER Basic Enviromental Co LLC
MAILING ADDRESS 875 W Warm Springs Rd
Henderson NV 89011

ADDRESS AT WELL LOCATION uinicorp county
MC-MW-34

2. LOCATION NE ¼ NE ¼ Sec 11 T 22S N/S R 62 E
PERMIT/WAIVER No. 178-11-501-006
issued by Water Resources Parcel No.

Latitude 36 03 16 37
Longitude 115 00 45.98
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County:

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... auger/sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silty sand w/gravel		0	20	20
gravel w/sand		20	35	15
silt w/gravel&sand		35	44	9
silty clay		44	50	6
fat clay		50	59	9

BCNR/DWR
RECEIVED
SEP 20 2011
LAS VEGAS OFFICE

Date started 23-Aug , 20
Date completed 25-Aug , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 59 Feet Depth Cased 56 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
18	Inches	0	Feet	36	Feet
6	Inches	36	Feet	59	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	28.55	.322	0	36
2.250	.56	.125	0	56

Perforations:
Type of perforation factory slotted
Size of perforation 0.010
From 46 feet to 56 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 42
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 45 feet to 57 feet

9. WATER LEVEL
Static water level 26.4 feet below land surface
Artesian flow n/a G.P.M n/a P.S.I
Water temperature n/a °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name W.D.C. Exploration & Wells
Contractor
Address 739 W Sunset
Contractor
Henderson NV 89011
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2371
Signed
By driller performing actual drilling on site or contractor
Date 9-19-11

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY