WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114 449
Permit No.
Basin 137 B

NOTICE OF INTENT NO. 63620

1. OWNER Kim Swearington (SWEARINGEN) (TA) 9/20/11
MAILING ADDRESS 8910 Western Skies Drive Reno Nevada 89521
ADDRESS AT WELL LOCATION 1 mile East of mile marker #75 HWY 376 Smokey valley

2. LOCATION SE ¼ SW ¼ Sec. 10 T. 14 N/S R. 43 E/W YE County
PERMIT NO. 0 (Issued by Water Resources) 010 441-45 (Parcel No.) Subdivision Name TWIST RANCH

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	110	110
Sand-Clay		110	115	5
Gravel-Boulders	X	115	125	10
Clay		125	130	5
gravel-sand	X	130	135	5
Clay		135	140	5

GPS WGS 84
N 39° 04.902'
W 117° 08.020'

RECEIVED
2011 SEP 26 AM 11:26
STATE ENGINEER'S OFFICE

Date started 8-28-2011, 20
Date completed 9-15-2011, 20

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	0	2
Flowing 150 Gpm		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	140

Perforations:
Type perforation factory
Size perforation 1/8" x 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 84
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 84 feet to 140 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 150 GPM G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on site or contractor
Date 9-18-2011

(Rev. 12-01) 39,081,780° N -117,133,574° W NAD27 (T2) USE ADDITIONAL SHEETS IF NECESSARY (O)-627