

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 114487  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35999

1. OWNER COUNTY OF CLARK ADDRESS AT WELL LOCATION Wetland Park Nature Center  
 MAILING ADDRESS 500 S. Grand Central Pkwy 7050 Wetland Park Lane  
LAS VEGAS, NV 89155 Las Vegas, NV  
 2. LOCATION NE 1/4 NW 1/4 Sec 26 T 21 S R 62 E CLARK County  
 PERMIT NO. DW1305 161-26-101-008  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Plug 1-Dewatering wells				
Pulled pump & casing Trimmie 1.5 yards of 9 sack cement grout into well to surface.				
WGS84 N36 05. 992' W115 01. 359'				
<b>DCNR/DWR RECEIVED</b>				
AUG 15 2011				
<b>LAS VEGAS OFFICE</b>				

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 0 Feet 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>0.250</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation Machine  
 Size perforation 1/4"x2.5"x21 per ft.  
 From 20 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7/29, 20 11  
 Date completed 8/1, 20 11

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
(CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE.  
(CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161-David Strouse  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date August 11, 2011