STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114517
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36048

1. OWNER Jose Rios / 7-Eleven, Inc
MAILING ADDRESS PO Box 711, Dallas TX 75221

ADDRESS AT WELL LOCATION 3520 E. Owens Ave
MW-2 Las Vegas , NV
Subdivision Name: County: Clark

2. LOCATION SW ¼ SW¼ Sec 19 T 20S N/S R 62 E
PERMIT/WAIVER No. 140-19-401-008
Issued by Water Resources Parcel No.

Latitude 36 11 18.88 Longitude 115 05 52.76
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	3"	3"
Road Base		3"	1'	9"
Silt. ML Pale Brown		1'	10'	10'
Silt. ML Light Brown	Moist	10'	14'	4'
Silty Sand	Wet	14'	19'	5'
Elastic Silt Very pale brown	Wet	19'	25'	6'

DCNR/DWR
RECEIVED
NOV 03 2011
LAS VEGAS OFFICE

Date started: 13-Oct , 20 11
Date completed: 14-Oct , 20 11

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	24	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.01	0.237	0	9

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.020
From 9 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout .05" to 5' ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 7' to 24' ☐ Pumped ☒ Poured
Type: #08 Sand
Bentonite Chips: ☒ Yes ☐ No 5' to 7' ☐ Pumped ☒ Poured
Type: 1/4" Medium Bentonite Chips

7. Water Level
Static water level: 14' feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	.5	4'	.50

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 739 W. Sunset Road, Henderson NV, 89011
Contractor

Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057-T1

Signed Bob
By driller performing actual drilling on site or contractor
Date 11/2/2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY