

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35886

1. OWNER LANNY D. LOVE ADDRESS AT WELL LOCATION LIDA RANCH LLC SERIES V
 MAILING ADDRESS PO Box 417, LAS VEGAS NV 89125 LIDA NEV 89013 - N. Side of State Route 266 @ LIDA
 2. LOCATION SE 1/4 SE 1/4 Sec. 35 T. 5 N/S R. 40 E. ESMEERALDA County
 PERMIT NO. 004-031-01 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	10	
Clay		10	17	
Gravel		17	20	
Boulders		20	120	
Sand & Gravel		120	125	
Hit Running sand at 115 ft				
Back filled to 125 ft with Gravel.				
LAT 37' 27" 28.52				
LONG 117-30 06.99				

8. WELL CONSTRUCTION
 Depth Drilled 125 Feet Depth Cased 125 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches 0 Feet 185 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>1.88</u>	<u>+1</u>	<u>125</u>

Perforations:
 Type perforation AIR PERFORATOR
 Size perforation 3/16 4 Times Around
 From 70 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 61.1 °F Quality _____

Date started 7-15-11, 20____
 Date completed 9-22-11, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name V.A. Dinnick Contractor
 Address 5740 N. Tee Pee Ln. NV. NV. 8949 Contractor
 Nevada contractor's license number 10062 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V.A. Dinnick By driller performing actual drilling on site or contractor
 Date 9-26-11

LAS VEGAS OFFICE

DCNR/DWR
 RECEIVED
 SEP 27 2011