ORIGINAL

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114562
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66664

1. OWNER: METALIC GOLDFIELD INC.
MAILING ADDRESS: 230 S. ROCK BLVD. SUITE 30, RENO NV, 89502

ADDRESS AT WELL LOCATION: McMAHON RIDGE AREA, MW - 13
Subdivision Name: County: Esmeralda

2. LOCATION SW ¼ NE ¼ Sec 19 T 02S N/S R 43 E
PERMIT/WAIVER No. M/O 1713 (Issued by Water Resources) Parcel No.

Latitude 37* 45.071 N
Longitude 117* 11.529 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY AND GRAVEL		0'	25'	25'
GREY CLAY		25'	50'	25'
RHYLOITE		50'	230'	

DCNR/DWR RECEIVED SEP 16 2011 LAS VEGAS OFFICE

Date started: 22-Aug, 20 11
Date completed: 23-Aug, 20 11

9. WELL CONSTRUCTION
Depth Drilled 220' Feet Depth Cased 210' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0'	Feet	20'	Feet
8"	Inches	20'	Feet	220'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"		.188"	+3'	20'
4"		SCH. 80	+2'	210'

Perforations:
Type of perforation: SCREEN
Size of perforation: 0.020"
From 110' feet to 210' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 20' ☒ Pumped ☐ Poured
☐ Cement Grout 20' to 95' ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100' to 220' ☐ Pumped ☒ Poured
Type: 8 X 16
Bentonite Chips: ☒ Yes ☐ No 95' to 100' ☐ Pumped ☒ Poured
Type: 3/8" HOLE PLUG

7. Water Level
Static water level: 60' feet below land surface
Artesian Flow: NO G.P.M. 0 P.S.I.
Water Temperature: COOL °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 HOURS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Hydro Resources-West, Inc. (Contractor)
Address: 4975 W. Winnemucca Blvd. (Contractor)
Winnemucca NV, 89445
Nevada contractor's license number issued by the *State Contractor's Board*: 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller*: # 1713
Signed: Michelle Strothey (By driller performing actual drilling on site or contractor)
Date: 9/13/2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY