

#9 of 10 wells under this project

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 114617
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36077

1 OWNER City of Las Vegas- Right of Way
MAILING ADDRESS 400 Stewart Ave
Las Vegas, NV 89101
ADDRESS AT WELL LOCATION NW Corner of Rancho & Washington
GAMW-5
Subdivision Name: County: Clark

2 LOCATION SE 1/4 NW 1/4 Sec 29 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-29-299-003
Latitude 36 10'52.21"N UTM E NAD 27
Longitude 115 10'47.21"W N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? No
If yes, what is replacement well NOI?
Is there an existing well log? N/A
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled Feet Depth Cased 24 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	0	24

Existing Perforations:

Type of perforation	Factory slotted
Size of perforation	0.02
From 9 feet to 24 feet	
From	
From	
From	
From	

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:

Additional Perforations:

Type of perforater used:	N/A
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot

5 WATER LEVEL
Static water level 13 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature ° F Quality

8 WELL PLUGGING MATERIALS

Material Used

From	feet to	feet	Portland Cement	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From 1	feet to 24	feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

6 Additional Notes or Comments

knocked out bottom of well, tremie grout from bottom up, pulled casing, concrete cap

DCNR/DWR RECEIVED
DEC 23 2011
LAS VEGAS OFFICE

Neat Cement Fluid Weight 5.2/94 lbs/gal
Bentonite Grout % bentonite
Date Started 12/14/2011
Date Completed 12/14/2011

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells Contractor
Address 739 W. Sunset Rd Contractor
Henderson, NV 89011
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 12-22-11

Rev. 05-09

USE ADDITIONAL SHEETS IF NECESSARY

36.181200°N
115.178945°W
NAD27
Dec/Dec