WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114621
Permit No.
Basin 212

NOTICE OF INTENT NO. 35485

1. OWNER ED GOEDHART
MAILING ADDRESS PO BOX 70
AMARGOSA VALLEY, NV 89020-0070

ADDRESS AT WELL LOCATION 320 E GAMEBIRD RD

2. LOCATION SE 1/4 SW 1/4 Sec. 34 T 20S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 40-702-12 (Parcel No.) UNIT 4A CALVADA VALLEY (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
6" PVC WELL		0	140	140
CLAY		140	155	15
CALICHIE	WB	155	160	5
CLAY		160	180	20
CALICHIE	WB	180	210	30
CLAY		210	225	15
CALICHIE	WB	225	240	15
CLAY		240	250	10
CALICHIE	WB	250	270	20
CLAY		270	285	15
CALICHIE	WB	285	300	15
N36°09'42.7"				
W116°00'27.4"				

DCNR/DWR
RECEIVED
NOV 10 2011
LAS VEGAS OFFICE

Date started 11/8/2011 , 19__
Date completed 11/8/2011 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	140	Feet
5-7/8	Inches	140	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	140
4	2.06	.237	140	300

Perforations:
Type perforation SCREEN
Size perforation .020
From 200 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 300 feet

9. WATER LEVEL
Static water level 67 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Qualify

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 11/8/2011

USE ADDITIONAL SHEETS IF NECESSARY