

Amended per Mario Romero
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Boart Longyear
 OFFICE USE ONLY
 Log No. 114645
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35049

1. OWNER CalNeu Pipe Line, LLC ADDRESS AT WELL LOCATION 3755 W. Hacienda Ave
 MAILING ADDRESS 1100 Town & Country Rd. Las Vegas, NV. 89118
Orange, CA 92664 Subdivision Name: _____ County: Clark

2. LOCATION NW 1/4 SW 1/4 Sec 29 T 21 N R 61 E Latitude 36.09342265 N UTM E NAD 27
 PERMIT/WAIVER No. 162-29 301-001 Longitude 115.1894067 W NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel cl		0	20	
cliche		20	30	
Gravel cl		30	35	
Sand silt cl		35	40	
cliche		40	45	
Gravel cl		45	47	
cliche		47	50	
Clay Gravel		50	60	
Sand silt		60	70	

9. WELL CONSTRUCTION

Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2 lbs</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations:
 Type of perforation factory slotted
 Size of perforation .020
 From 25 feet to 70 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 1 to 20 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 23 to 70 Pumped Poured
 Type: Sand #3 RunC

Bentonite Chips: Yes No 20 to 23 Pumped Poured
 Type: 3/8 medium w/40 BEN

7. Water Level
 Static water level: 42 feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: Cold °F
 Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bail & Pump</u>	<u>2.5</u>		<u>2 hrs</u>

DCNR/DWR RECEIVED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear
 Address 1333 W. 9th St.
Upland, CA 91786
 Nevada contractor's license number 0021976
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2438
 Division of Water Resources, the on-site driller

Signed [Signature] BLK Contractor
 By driller performing actual drilling on site or contractor

Date 10-24-11 Revised 12-22-11

LAS VEGAS OFFICE



**BOART
LONGYEAR**

C57 #694686

Boart Longyear E. I. Division

1333 W. 9th St

Upland Calif. 91786

Tel: 909-946-1605 • Fax: 909-946-1608

www.boartlongyear.com

To whom it may concern

Attn: Steven Martinez

Please replace previous submitted Well Reports with the revised ones attached as the owner information was incorrect.

Let me know if any questions

Thanks,

Mario Romero

909-946-1640

**DCNR/DWR
RECEIVED**

FEB 23 2012

LAS VEGAS OFFICE