

Amended

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 114653
Permit No. 212
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35057

1 OWNER Cal Nev Pipe Line, LLC ADDRESS AT WELL LOCATION Row E. of 525 S.
MAILING ADDRESS 1100 Town & Country Rd Valley View Blvd Las Vegas, NV 89119
Orange, CA 92468
Subdivision Name County Clark
2 LOCATION SE 1/4 NE 1/4 Sec 30 T 21 N 01 E Latitude 36.0944 UTM E NAD 27
PERMIT/WAIVER No. 1162-30-699-017 Longitude -115-14996 N NAD 83/WGS 84
issued by Water Resources Parcel No.

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? no
 Domestic Irrigation Test If yes, what is replacement well NOI?
 Municipal/Industrial Monitor Stock If yes, what is NDWR well log #? 45649

4 EXISTING WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet	
EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5			0	75

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforater used:
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
		From	feet to	feet
		From	feet to	feet
		From	feet to	feet
		From	feet to	feet

5 WATER LEVEL
Static water level 40.0 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From 0	feet to 75	feet	Neat cement	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
-Not able to pull PVC casing-

Neat Cement Fluid Weight 94.0 lbs/gal 5.2
Bentonite Grout 5 % bentonite
Date Started _____
Date Completed _____

DCNR/DWR RECEIVED
FEB 23 2012
LAS VEGAS OFFICE

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Co. Contractor
Address 1333 W. 9th St Contractor
Upland, CA 91786
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2434
Signed [Signature] BLY contractor
By driller performing actual drilling on site or contractor
Date 2-21-12 Revised



**BOART
LONGYEAR**

C57 #694686

Boart Longyear E. I. Division

1333 W. 9th St

Upland Calif. 91786

Tel: 909-946-1605 • Fax: 909-946-1608

www.boartlongyear.com

To whom it may concern

Attn: Steven Martinez

Please replace previous submitted Well Reports with the revised ones attached as the owner information was incorrect.

Let me know if any questions

Thanks,

Mario Romero

909-946-1640

**DCNR/DWR
RECEIVED**

FEB 23 2012

LAS VEGAS OFFICE