STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114773
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36107

1. OWNER BRUNER + PLACID LLC / JOSE RIOS - 7-ELEVEN
MAILING ADDRESS PO Box 711, Dallas TX 75221

ADDRESS AT WELL LOCATION S / E Corner Belmont & N. LV BLVD
MW-24 Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION NW ¼ SE ¼ Sec 13 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-13-702-001
Issued by Water Resources Parcel No.

Latitude 36 12 33.72
Longitude 115 06 24.97
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt Brown		0	43'	43'
Poorly Grated Sand w Silt	Wet	43'	49'	6'
Silty Sand Pnkish Grey	Wet	49'	54'	5'
Silty Clay Light Grey	Wet	54'	58'	4'
Silty Sand White	Wet	58'	62'	4'
Silty Sand Hard White	Wet	62'	65'	3'

DCNR/DWR
RECEIVED
NOV 08 2011
LAS VEGAS OFFICE

Date started: 25-Oct, 20 11
Date completed: 26-Oct, 20 11

9. WELL CONSTRUCTION
Depth Drilled 10/25/11 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	65	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.68	0.154	0	65
2.375	.68	0.154	0	55

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.020
From 60 feet to 65 feet
From 50 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 0.05' to 43' ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 61'/48' to 65'/56' ☐ Pumped ☒ Poured
Type: #08 Sand
Bentonite Chips: ☒ Yes ☐ No 9' to 11' ☐ Pumped ☒ Poured
Type: TR-30 1/4" Pellets 59' to 56' - 1/4' Bent Chips 48' to 43'

7. Water Level
Static water level: 22.5' feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	.5	4'	.50

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 739 W. Sunset Road, Henderson NV, 89011 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057-T1
Signed Bob (By driller performing actual drilling on site or contractor)
Date 11/2/2011

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY