STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114798
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66762

1. OWNER Pauline Lambert & Victor
MAILING ADDRESS 4085 Lambert Dr. Winnemucca NV. 89445
ADDRESS AT WELL LOCATION 3440 Georgia Circle Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION NE¼ SW¼ Sec 10 T 37 N/S R 38 E
PERMIT/WAIVER No. 006-6012-45 (Issued by Water Resources) Parcel No.
Latitude N41° 05.743 Longitude W117° 41.378
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	5	5
Sand Clay	NO	5	15	10
Gravel Sand Clay	NO	15	60	45
Gravel Sand	yes	60	100	40

Date started: 4-16-11, 20
Date completed: 4-20-11, 20

7. Water Level
Static water level: 52 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	0	3½
	41.095815	NAD 27
	117.689005	

9. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10⅞ Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	.188	Steel	0	20
6⅝	Schedule 40	PVC	20	100

Perforations:
Type of perforation Slot
Size of perforation .25
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 100 ☐ Pumped ☒ Poured
Type: 3/8" Pea gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Alternative Drilling (Contractor)
Address 197 Western Hills (Contractor)
Spring Creek NV.
Nevada contractor's license number issued by the State Contractor's Board 0007395 5
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed Gerald Moritz (By driller performing actual drilling on-site or contractor)
Date 4-24-11

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627