STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114801
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67608

1. OWNER JAVIER PEREZ + Maria Perez
MAILING ADDRESS P. O. BOX 3626
WENDOVER, NV 89883

ADDRESS AT WELL LOCATION HERFORD DRIVE
Lot 6, Block 30
Subdivision Name: Meadow Valley Rancho #3 County: ELKO

2. LOCATION NE ¼ NW ¼ Sec 10 T 35N N/S R 56 E
PERMIT/WAIVER No. 035-030-006
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0613281 [X] NAD 27
N 4532957 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	9	9
GRAVEL	X	9	40	31
COARSE SAND		40	45	5
TAN SHALE		45	95	50
SAND	XX	95	120	25

RECEIVED 2012 FEB 24 PM 1:14 STATE ENGINEERS OFFICE

Date started: 17-Jan, 20 12
Date completed: 17-Jan, 20 12

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	120

Perforations:
Type of perforation PLASMA CUT
Size of perforation 1/8" X 4", 6 ROWS
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 3 to 50 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 120 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 31 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 50 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
825 CFM @ 90 PSI	35		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1408
Signed (By driller performing actual drilling/on site or contractor)
Date 1/17/2012

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

40.941806
115.654282 NAD27