WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114933
Permit No. 53785
Basin 162

NOTICE OF INTENT NO. 35490

1. OWNER ESCAPEES CO-OP
MAILING ADDRESS 5150 S OAKRIDGE AVE
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 5150 S OAKRIDGE AVE

2. LOCATION NE 1/4 NW 1/4 Sec. 12 T 21 N/S R 53 E NYE County
PERMIT NO. 53785 (Issued by Water Resources) 44-511-06 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED - DSB
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GILL DIRT & GRAVEL		0	4	4
CLAY		4	18	14
CALICHIE		18	25	7
CLAY		25	70	45
CALICHIE	WB	70	90	20
CLAY		90	120	30
CALICHIE	WB	120	135	15
CLAY		135	148	13
CALICHIE	WB	148	160	12
CLAY		160	180	20
CALICHIE	WB	180	210	30
CLAY		210	230	20
CALICHIE	WB	230	245	15
CLAY		245	270	25
CALICHIE	WB	270	315	45
CLAY		315	335	20
CALICHIE	WB	335	350	15
CLAY		350	360	10
CALICHIE	WB	360	375	15
SOFT CLAY		375	400	25

N36°08'41.734"
W115°58'13.119"

CONCRETE SEAL 0-50'
BENTONITE SEAL 50'-215'

Replacement Reggeng of original log #29438

Date started 1/26/2012, 19__
Date completed 1/27/2012, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
RECEIVED
FEB 09 2012

8. WELL CONSTRUCTION

Depth Drilled 385 Feet Depth Cased 385 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

[redacted]

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	385

Perforations:
Type perforation SCREEN
Size perforation .032
From 245 feet to 385 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 215
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 215 feet to 385 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 2/3/2012

USE ADDITIONAL SHEETS IF NECESSARY

LAS VEGAS OFFICE