

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 115672
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **36205**

1. OWNER **JACKIE & DENNIS JENSEN**
 MAILING ADDRESS **1821 W CALVADA BLVD**
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION **1821 W CALVADA BLVD**

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T 20
 PERMIT NO. 40-242-18
Issued by Water Resources Parcel No.

MSR 53 E NYE County
UNIT 5 CALVADA VALLEY
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		140	165	25
CALICHIE	WB	165	184	19
CLAY		184	213	29
CALICHIE	WB	213	231	18
CLAY		231	240	9

N36°10'59.5"
 W116°02'47.5"

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>7-7/8</u> Inches	<u>140</u> Feet	<u>240</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2.37</u>	<u>.248</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation **FACTORY SLOTTED**
 Size perforation .032
 From 200 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **EXISTING**
 Placement Method: Pumped Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From **SURFACE** feet to 240 feet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
Contractor
 Address **1220 MANSE RD**
Contractor

PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date **4/17/2012**

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR
 RECEIVED

APR 23 2012

LAS VEGAS OFFICE

Date started 4/17/2012, 19
 Date completed 4/17/2012, 19