STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115128
Permit No.
Basin 189A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67483

1. OWNER Walker/Winecup Ranch
MAILING ADDRESS 3801 PGA Blvd, Ste 910
Pam Beach, FL 33410

ADDRESS AT WELL LOCATION Winecup Ranch
Main Ranch House

2. LOCATION NW¼ NW ¼ Sec 25 T 41H N/S R 64 E
PERMIT/WAIVER No. _____ Issued by Water Resources
Parcel No.

Latitude 41°24'8817
Longitude 114°41'162
UTM E _____ N _____
☐ NAD 27 ☒ NAD 83/WGS 84
Subdivision Name: None
County: Elko

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	4	4
Clay Sand Mix		4	115	111
Gravel and Sand	x	115	117	2
Clay and Sand Mix		117	124	7
Gravel and Sand	x	124	126	2
Clay and Sand Mix		126	131	5
Gravel and Sand	x	131	132	1
Hard Ceyel Clay		132	163	31

Date started 12/2/2011 , 20
Date completed 12/12/2011 , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Apad	120		4

8. WELL CONSTRUCTION
Depth Drilled 163 Feet Depth Cased 163 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0	Feet	163	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	23
6	PVC	SDR-17	23	163

Perforations:
Type of perforation Screen
Size of perforation 0.032
From 103 feet to 123 feet
From 143 feet to 163 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 25'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 55 feet to 163 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow 0.75 G.P.M 1 P.S.I
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig, dba Fertig Drilling Company (Contractor)
Address P.O. Box 525 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-23-11

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

41.414776°N
114.685164°W NAD27