STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115132
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67618

1. OWNER ARNOLD BECK CONSTRUCTION
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 473 DRY CREEK TRAIL
ELKO, NV
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SW ¼ SW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09P-031
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0601898 ☒ NAD 27
N 4516958 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALUVIUM		0	25	25
GREEN GREY CLAY		25	70	45
BLUE GREY CLAY		70	170	100
LIGHT GREY SHALE		170	190	20
LT GREY SHALE & SANDSTONE	XXX	190	220	30

RECEIVED 2012 MAY -4 AM 11:16 STATE ENGINEERS OFFICE

Date started: 30-Apr, 20 12
Date completed: 30-Apr, 20 12

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	220

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 4 to 15 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 220 to 50 ☐ Pumped ☒ Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 15 to 50 ☐ Pumped ☒ Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 64 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
825 cfm @ 125 psi	60	2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1408
Signed (By driller performing actual drilling on site or contractor)
Date 5/2/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

40.799208°N
115.792097°W
NAD27