STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115186
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 66070

1. OWNER City of Sparks
MAILING ADDRESS 431 Prater Way, Sparks, Nevada 89431

ADDRESS AT WELL LOCATION
Steniri & Snider Way, Sparks, Nevada

2. LOCATION NW¼ SE ¼ Sec 9 T 19N N/S R 20 E
PERMIT/WAIVER No. DEW-093A (Issued by Water Resources) Parcel No.

Latitude 39° 31.582 Longitude 119° 44.524
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Washoe

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Other... Dewatering

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Road base | | 0 | 4 | 4 |
| Clay | | 4 | 8 | 4 |
| Cobble and Sand | X | 8 | 25 | 17 |

Date started 21-May, 20 12
Date completed 23-May, 20 12

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 25 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 16 | | .250 | 0 | 25 |
| | | | | |
| | | | | |

Perforations:
Type of perforation Mill Slot
Size of perforation 0.09
From 0 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 0 feet to 25 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Stonehouse Drilling & Construction, LLC (Contractor)
Address 7801 Lakeside Drive (Contractor)
Reno, Nevada 89511
Nevada contractor's license number issued by the *State Contractor's Board* 0069994
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2019
Signed (By driller performing actual drilling on site or contractor)
Date 1-Jun-12

RECEIVED 2012 JUN -5 AM 10:39 STATE ENGINEER'S OFFICE

(Rev. 06/10) USE ADDITIONAL SHEETS IF NECESSARY

39.526455°N
119.741045°W
NAD27