STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115305
Permit No.
Basin 173B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68007

1. OWNER Jackie Reynolds Ranch
MAILING ADDRESS HC 34 Box 34425
Ely, NV 89301

ADDRESS AT WELL LOCATION 1 Mile north of mile marker 113 Hwy 6
Subdivision Name: County: Nye

2. LOCATION NE ¼ NE ¼ Sec 27 T 10 N/S R 57 E
PERMIT/WAIVER No. R30-2012-10 013-121-03
Issued by Water Resources Parcel No.

Latitude 38° 42.309 Longitude 115° 32.480
UTM E N ☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Silt		0	10	10
Sand, Gravel		10	120	110
Gravel		120	180	60
Sand, Gravel		180	200	20

RECEIVED 2012 JUN 21 AM 11:53 STATE ENGINEERS OFFICE

Date started: June 13, 2012
Date completed: June 14, 2012

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.002	.250	+18"	20'
6.625	5.006	.390 (SDR17)	20	200

Perforations:
Type of perforation Mill
Size of perforation 1/8" x 2 1/2
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type: Pea gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 64 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HOUR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling, Inc. (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2459
Signed Trevor Gardner (By driller performing actual drilling on-site or contractor)
Date June 19, 2012

USE ADDITIONAL SHEETS IF NECESSARY

38.705150 °N
115.541333 °W NAD27

(Rev. 05-06) (NSPO 3-08) (O) 627