

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 115312  
Permit No. \_\_\_\_\_  
Basin 045

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67988  
Rabbit Creek Rd

1. OWNER Matt Anderson  
MAILING ADDRESS P.O. Box 281382  
Lamoille, NV 89828

ADDRESS AT WELL LOCATION  
Subdivision Name: \_\_\_\_\_ County: Elko

2. LOCATION SW 1/4 NE 1/4 Sec 23 T 33 N R 51 E  
PERMIT/WAIVER No. 006-520-044 ~~1006-520-062~~  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude W 115° 31.062 UTM E  NAD 27  
Longitude N 40° 43.879 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>alluvial sands/gravel</u>		<u>0</u>	<u>60</u>	<u>60</u>
<u>sands/gravel</u>		<u>80</u>	<u>180</u>	<u>120</u>
		<u>120</u>		
		<u>160</u>		

9. WELL CONSTRUCTION

Depth Drilled	<u>180</u>	Feet	Depth Cased	<u>180</u>	Feet
---------------	------------	------	-------------	------------	------

HOLE DIAMETER (BIT SIZE)

	From	To		
<u>10 5/8</u>	<u>0</u>	<u>180</u>	Inches	Feet
			Inches	Feet
			Inches	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>180</u>

Perforations:

Type of perforation mill slot  
Size of perforation 3/16 x 3

From 160 feet to 180 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 0 to 15  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 180  Pumped  Poured  
Type: pea gravel  
Bentonite Chips:  Yes  No 15 to 50  Pumped  Poured  
Type: 3/8 chips

Date started: 5.29 .20 12  
Date completed: 5.29 .20 12

7. Water Level  
Static water level: 80 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: cold °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<u>70</u>		<u>4</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Alternative Drilling Co LLC Contractor  
Address P.O. Box 281166 Contractor  
Lamoille, NV 89828

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 73955  
Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 2465

Signed Jozan Rashid  
By driller performing actual drilling on-site or contractor  
Date 6-11-12

RECEIVED  
2012 JUN 28 AM 11:0  
STATE ENGINEERS OFFICE

40.731390°N  
115.516806°W NAD27

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-00)

(NSPO 3-08)