

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. LE3117

1. OWNER Patrick Phamey Edgewood ADDRESS AT WELL LOCATION Edgewood 180 Lake Parkway Dr  
 MAILING ADDRESS 300 Burkett Rd. S.A. Minden NV 89423 State Line NV  
 2. LOCATION NE 1/4 NE 1/4 Sec. 27 T. 13 S. R. 18 E. Douglas County  
 PERMIT NO. MA 1705 ANN 1318-27-001-001 119° 50' 15.117" W 38° 58' 1.060" N NAD 27  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown silt		6	10	10
Grey silt		10	16	6
gravel	17.5	16	18	2
decomposed granite		18	20	2

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>DVC</u>	<u>Sch 40</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation pac  
 Size perforation 0.70  
 From 15 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 10 feet to 20 feet

9. WATER LEVEL  
 Static water level 17.5 feet below land surface  
 Artesian flow NA G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality N/A

Date started 12/15, 2011  
 Date completed 12/15, 2011

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>N/A</u>		<u>38. 966961' N NAD 27</u>	
		<u>119. 937532' W</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andresen Drilling Contractor  
 Address 11635 Belford rd. Reno NV 89509 Contractor  
 Nevada contractor's license number 34525 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 1/6/12