

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115359
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68624

1. OWNER Perazzo Brothers ADDRESS AT WELL LOCATION 6555 Stillwater St.
MAILING ADDRESS 6555 Stillwater Rd. Fallon, NV 89406
Fallon, NV 89406 Subdivision Name: _____ County: Churchill

2. LOCATION SW 1/4 NW 1/4 Sec 30 T 19N N/S R 30 E Latitude 39.48435 N UTM E NAD 27
PERMIT/WAIVER No. 009-101-04 Longitude -118.66700 W N NAD 83/WGS 84
Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	37	37
Brown Clay		37	42	5
Green Sand		42	53	11
Green Clay		53	56	3
Black Sand		56	59	3
Black Clay		59	64	5
Green Clay		64	84	20
Fine Green Sand		84	88	4
Green Clay		88	94	6
Green Sand Fine		94	106	12
Black Clay		106	111	5
Black Sand		111	123	12
Green Clay		123	132	9
Green Sand Fine		132	156	24
Black Clay		156	161	5
Black Sand		161	174	13
Green Clay		174	193	19
Green Sand		193	210	17
Green Course Sand		210	230	20
Black		230	237	7
Green Clay		237	241	4
Green Sand		241	250	9

9. WELL CONSTRUCTION

Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

From	To	From	To
<u>14</u> Inches	<u>0</u> Feet	<u>250</u> Feet	<u>250</u> Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>22.36</u>	<u>.250</u>	<u>0</u>	<u>18</u>
<u>8.625</u>	<u>8.76</u>	<u>.508</u>	<u>18</u>	<u>250</u>

Perforations:

Type of perforation Saw Cut
Size of perforation 0.125

From	feet to	From	feet to
<u>245</u>	<u>250</u>	<u>250</u>	<u>250</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Annular Seal: Yes No

<input checked="" type="checkbox"/> Neat Cement	<u>10</u> to <u>0</u>	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	_____ to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	_____ to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> 230% Bentonite Grout	<u>10</u> to <u>140</u>	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 140 to 10 Pumped Poured
Type: 3/8" well gravel

Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

Date started: 27-Dec, 2011
Date completed: 30-Dec, 2011

7. Water Level
Static water level: 14 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA

TEST METHOD: Baller Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>45</u>	<u>1</u>	<u>1</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor

Address P.O. Box 1265
Contractor
Fallon, NV 89407

Nevada contractor's license number
Issued by the State Contractor's Board 29064

Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 2307

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 1/6/2012

(Rev. 05-08) 39.484431 °N
118.666019 °W NAD27

USE ADDITIONAL SHEETS IF NECESSARY