STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115367
Permit No. 69713R08 (82063)
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68916

1. OWNER ARTISAN COMMUNITIES LLC
MAILING ADDRESS 4940 LEO BINGO COURT
WASHOE VALLEY, NV 89704

ADDRESS AT WELL LOCATION 255 HAMILTON CREEK COURT
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SW ¼ NW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 69713R08 (82063) 006-09P-062
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0601843 [X] NAD 27
N 4517733 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic QM [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	4	4
GRAVEL & SAND		4	35	31
GREEN CLAY		35	80	45
LT GREEN CLAY		80	90	10
GREY CLAY		90	145	55
BLACK VOLCANIC	XXX	145	165	20
BLACK VOLCANIC w/ GREY CLAY		165	180	15

RECEIVED 2012 JUL 18 PM 1:10 STATE ENGINEERS OFFICE

Date started: 12-Jul, 20 12
Date completed: 12-Jul, 20 12

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	180

Perforations:
Type of perforation PLASMA CUT
Size of perforation 5/16" X 4", 7 ROWS
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 15 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 180 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 15 to 50 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 48 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
110 PSI @ 825 CFM	80		1 HOUR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1408
Signed (By driller performing actual drilling on site or contractor)
Date 7/13/2012

(Rev. 05-08) 40.806195°N NAD 27
115.792622°W

USE ADDITIONAL SHEETS IF NECESSARY